

# Emission Test Certificate

Thursday March 22<sup>nd</sup>, 2007

Supplier: Verosol Australia Pty Ltd

2 Garema Circuit

Kingsgrove New South Wales 2208

Sample Description: PVC/fiberglass blind fitting

Date Tested: March 2007

Test Method: ASTM D5116-97 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<b>Green Building Council of Australia Green Star Office Interior Specification</b>	<b>Total Volatile Organic Compound Specific Area Emission Rate</b>
< 0.5 mg/m <sup>2</sup> /hr (7 days)	0.05 mg/m <sup>2</sup> /hr



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant